



**February 21, 2019
Newberry County
Purchasing Department**

**ADDENDUM ONE
Invitation for Bids No.: 2019-1
Springhill Drive Road Repairs**

The following shall be incorporated into the response for the mentioned solicitation:

Questions were presented:

1. What curing method is to be used for Cement Mod Recycled Base?
The CMRB will be cure for utilizing water.
2. What is the LF for the striping? Are RPMs needed, if so, what is quantity?
The linear footage for white shoulder line is 8,600 feet (total) and 4,225 of double yellow lines.
No RPMs.
3. Is there any milling to be performed or is this scope to be included in the CMRB price?
The only milling to be done will be included within the scope of the CMRB.

Additionally, the pounds per square yard will change from 150 to 175 lbs.

End of Addendum

Crystal Waldrop
Crystal Waldrop, CPPB
Purchasing Director

2-21-19

Date