

# SECTION 00 90 10 ADDENDUM NO. 5

Project: Gallman Place Roof Renovation  
Newberry, SC 29108  
23234 – A

Date: 5 May 2026

To: All Bid Document Holders

This Addendum forms a part of the contract documents and modifies the bidding documents with amendments and additions noted below.

Acknowledge receipt of this addendum in the space provided in the bid form. Failure to do so may render the bid unresponsive.

Manufacturers and products indicated as an “approved substitution” shall be accepted as equal for the manufacturers given in the contract documents. It is understood that the products submitted for these manufacturers must still meet the specifications of the project, and can be rejected if after review, are determined to be not equal to the product called out in the contract documents.

## GENERAL

- Question 1 Received: “There appears to be slope in the deck, no core cuts were made in the field to determine if the taper is in the deck or the insulation. If the taper is in the deck do you still require a ¼” Taper package?”
  - Response: *Assume no slope in the deck. Tapered insulation is still required.*
- Question 2 Received: “In reference to the Bid Form Insurance Requirements, can I add the waiver of subrogation to the workers compensation policy after contract award?”
  - Response: *Yes you can; please include a written statement from your insurance certifying that the waiver of subrogation to the workers compensation policy will be included after the contract award.*

**END OF SECTION**

DP3 Architects, Ltd.  
15 South Main Street  
Suite 400  
Greenville, SC 29601  
864.232.8200

[www.DP3architects.com](http://www.DP3architects.com)